

ATTESTATION OF CONFORMITY

1085-0931

by certification body „OFI CERT“ regarding the hygiene suitability for drinking water of

Multilayer hose TUSIL ACQUA

(see appendix 1)

under **SYSTEM 1+** with external monitoring of the following production sites

of the manufacturer

Tubigomma Dergibus S.r.l.
Via E. Mattei 1
35030 Saccolongo, Padova, ITALY

produced at the production site

Tubigomma Dergibus S.r.l.
Via E. Mattei 1
35030 Saccolongo, Padova, ITALY

We hereby certify that the product / component indicated above

- based on the certification programme ZI-21 (OFI CERT)
- the submitted product information, including the formulation details
- and the assessment documents (OFI 2302009 / 21950)

meets the requirements of the „Umweltbundesamt - Evaluation criteria for plastics and other organic materials in contact with drinking water (KTW-BWGL)“ (rev. 2022-03-07) for the product group “Pipes” and application temperature 23°C (cold water) and is in compliance with the above documents.

The assessment documents¹⁾ are part of this attestation of conformity. This attestation of conformity was issued for the first time on 2024-04-22 and is valid from the date of issue below until 2029-04-22. Additionally, the preconditions specified below under „Remarks“ have to be fulfilled.

Remarks:

The attestation of conformity is issued under the precondition that the starting materials used to manufacture the products and /or their composition and/or components, including their manufactures and supply chain, have been disclosed in full and the product does not contain any further substances. This document shall be invalid in case of changes to the composition of the product or the processing conditions that have not been agreed upon with the certification body, failure to meet the conformity requirements or termination of the 1+ system monitoring programme by OFI CERT and manufacturer.

The finding of our tests and the evaluations apply for the test objects examined and the provisions of the law applicable at the time of testing. Without our express written approval, it is only permitted to publish or reproduce this document in full and unedited.

Vienna, 22nd of April 2024
(supersedes version from: new edition)



The certificate is listed at
www.ofi.at/zertifizierung.
1) The assessment documents are
Kept on file in OFI CERT and are
only used in justified cases
(e.g. at the request of an authority).

www.ofi.at
Certification Body OFI CERT
OFI Technologie & Innovation GmbH
Franz-Grill-Str. 5, Obj. 213
1030 Vienna | AUSTRIA



ATTESTATION OF CONFORMITY

Annex 1

(Attestation of Conformity 1085-0931)

Additional information

Product group	Cold water (23°C)	Warm water (60°C)	Hot water (85°C)
Pipes (P1)	pass	---	--

Material (in contact with drinking water)¹:

Silicone liner

Dimensions

ID/OD [mm] 10/19 up to 80/97

¹ Acc. to BOM-list of producer

Vienna, 22nd of April 2024
(supersedes version from: new edition)



The certificate is listed at
www.ofi.at/zertifizierung.
1) The assessment documents are
kept on file in OFI CERT and are
only used in justified cases
(e.g. at the request of an authority).

www.ofi.at
Certification Body OFI CERT
OFI Technologie & Innovation GmbH
Franz-Greif-Str. 5, Obj. 213
1030 Vienna | AUSTRIA

